



2026 Prescriptive Program Measure Selection Form: HVAC for Indiana businesses

Complete this Measure Selection Form to apply for an incentive for the installation of eligible HVAC measures installed by **December 15, 2026**.

- All technical data sheets for installed equipment must be included with your submission.
- If technical data (EER, Efficiency, etc.) requested in the form is unavailable, please contact your product supplier. Incomplete forms will not be processed.
- All installed measures must be new. No refurbished measures will be accepted.
- **For new construction or major renovation installations:**
 - VFD measures must exceed ASHRAE 90.1-2007
 - Chiller measures must exceed ASHRAE 90.1-2016
 - The following measures must exceed Federal Standards: PTHP, Air Conditioners, and Heat Pumps.

Important

This Measure Selection Form and technical data sheets should be submitted in conjunction with the **Prescriptive Program Application**.

Applications for incentives greater than \$20,000 or energy savings greater than 1 GWh per facility per year must be preapproved by Indiana Michigan Power prior to purchasing or installing equipment.

Need help?

For assistance completing this Measure Selection Form, call **800-929-7633** to speak with a program representative.

Project & Facility Information (Required Information)

Please select the HVAC and building type where all measures are being installed. If measures are being installed in more than one building type, please complete additional measure selection forms.

Project Type

- Retrofit Existing Equipment
- Replace Failed Equipment
- New Load
- New Construction or Major Renovation

Heating/Cooling Type

- AC with Natural Gas Heat
- AC with Electric Heat
- Heat Pump
- Electric Heat Only

Project & Facility Information (cont.)

Building Type

Assisted Living	Grocery	Office (Small < 50,000 sf)
Auto Repair	Healthcare Clinic	Office (Large ≥ 50,000 sf)
Convenience Store	Hospital	Religious Building
Drug Store	Industrial	Restaurant
Education (College)	1-Shift 2-Shift 3-Shift 24/7	Retail (Small < 50,000 sf)
Educational (preK-8)	Multifamily	Retail (Large ≥ 50,000 sf)
Educational (High School)	Hotel/Motel - Guest	Warehouse/Storage
Emergency Services	Hotel/Motel - Common	Other

Select HVAC System Type and Purpose for Chiller, Chiller Tune-up, or VFD Projects Only

HVAC System Purpose

- Space Conditioning (equipment used only to condition the space)
- Process Cooling (equipment used strictly to cool a product as part of the manufacturing process)
- Combined Space Cond. and Process Cooling (equipment serves both space conditioning & process loads)

Thermostats

Ref ID	Equipment Specifications	Unit	Make and Model	Quantity	Incentive (Per Unit)	Total Incentive	
TST-01	Smart or Programmable Thermostat	Each			\$50	\$	
Cooling Controlled?		Controlled Cooling Capacity (tons)		Heating Controlled?	Natural Gas Heat Capacity (kBtu/h)	Heat Pump Capacity (tons)	Electric Resistance Capacity (kW)
Yes	No			Yes	No		
<ul style="list-style-type: none"> Primary heating or cooling source of the controlled equipment must be electric. Systems with only natural gas heat are not eligible. Compared to the occupied temperature, the unoccupied temperature must be ≥3 degrees warmer in the summer and ≥3 degrees cooler in the winter. The existing or baseline thermostat is either a manual thermostat or a programmable thermostat that is not currently scheduled during unoccupied hours. 							

Packaged Terminal Heat Pumps

Equipment must replace a packaged terminal air conditioner with electric resistance heating.

Ref ID	Equipment Type	Equipment Cooling Capacity (Btu/h)	Cooling Efficiency (EER)	Equipment Heating Capacity (Btu/h)	Heating Efficiency (COP)	Quantity	Incentive (Each)	Total Incentive
PHP-01	Packaged Terminal Heat Pump						\$250	\$

Product Information

Ductless Mini-Split Air Conditioner or Heat Pump

Must submit an AHRI Certificate (or submittal sheet) for installed model showing the rated efficiency level(s). Must be a ductless unit. Ducted units should be submitted for the Air Conditioner <65,000 Btu/h or Air Source Heat Pump <65,000 Btu/h measure, respectively.

Ref ID	Equipment Type	Unit	Minimum Efficiency	Make & Model	Cooling Capacity (Btu/h)	Quantity	Incentive (Per Unit)	Total Incentive
MS-01	Ductless Mini-Split Air Conditioner	Each	18.0 SEER2				\$40	\$
MS-02	Ductless Mini-Split Heat Pump	Each	18.0 SEER2 8.0 HSPF2				\$60	\$

Air Conditioners and Heat Pumps

The air conditioner and heat pump measures apply to split systems, packaged units, and ducted mini-split units. Must submit an AHRI Certificate (or submittal sheet) for installed model showing the rated efficiency level(s).

Ref ID	Equipment Type	Equipment Size	Min. Efficiency	Size (Tons)	Quantity	Total Tons	Incentive (Per Ton)	Total Incentive
AC-01		<65,000 Btu/hr (5.4 tons)	16.0 SEER2				AC Only: \$20	\$
HP-01			8.0 HSPF2				ASHP: \$40	
AC-02	Air Conditioner or Air Source Heat Pump (ASHP)	65,000 Btu/hr (5.4 tons) - 134,999 Btu/hr (11.3 tons)	16.0 IEER				AC Only: \$20	\$
HP-02			3.5 COP				ASHP: \$40	
AC-03		135,000 Btu/hr (11.3 tons) - 239,999 Btu/hr (20 tons)	15.4 IEER				AC Only: \$20	\$
HP-03			3.4 COP				ASHP: \$40	
AC-04		≥240,000 Btu/hr (20 tons)	15.4 IEER				\$20	\$
HP-05	Water Source Heat Pump	≤135,000 Btu/hr (11.25 tons)	15 EER 5.0 COP				\$40	\$

Product Information (cont.)

Air Conditioner Tune-Up

Air Conditioner Tune-Ups shall include checking for refrigerant charge, identify and repair leaks if refrigerant charge is low, measure and record refrigerant pressures, measure and record temperature drop at indoor coil, clean condensate drain line, clean condenser coil and straighten fins, clean supply air fan blades, clean condenser fan blades, repair damaged insulation on suction line, change air filters (twice per year), measure and record blower amp draw, clean evaporator coil with spray-on cleaner and straighten fins (optional), and verify economizer operation & fix or adjust as needed (if air conditioner has an economizer).

Ref ID	Measure Name	Unit	Air Conditioner Make & Model Number(s)	Evaporator Coil(s) Cleaned?		Capacity (Tons)	Quantity	Incentive (Per Ton)	Total Incentive
AC-05	Air Conditioner Tune-Up	Ton		Yes	No			\$10	\$
<ul style="list-style-type: none"> • Rebate is available once per year for each air conditioner. • Condenser and evaporator coils must be cleaned. • Window units are ineligible for rebate. • Calculated incentive capped at 100% of tune-up cost. • New construction projects are ineligible for rebate. • Apply for Furnace Tune-Up, Refrigerant Charge, Packaged Rooftop Unit Sealing, & Economizer Repair & Optimization measures separately, as they apply. 									

Refrigerant Charge

Ref ID	Measure Name	Unit	Air Conditioner Make & Model Number(s)	LBs Refrigerant Added	Capacity (Tons)	Incentive (Per LB)	Total Incentive
AC-06	Refrigerant Charge	LB Refrigerant				\$6	\$
<ul style="list-style-type: none"> • Rebate is available once per year for each air conditioner. • Refrigerant leak must be located and fixed. • Window units are ineligible for rebate. • Calculated incentive capped at 100% of product cost. • New construction and new load projects are ineligible for rebate. 							

Product Information (cont.)

Economizer Repair & Optimization

Ref ID	Equipment Type	Unit	Economizer Control Type (Select One)	Air Conditioner Make & Model Number(s)	Incentive (Per Ton)	Total Incentive
AC-07	Economizer Repair & Optimization	Ton	Fixed Dry-Bulb Dual Temperature Dry-Bulb Differential Enthalpy Fixed Enthalpy		\$10	\$
Value						
Economizer Control Details (Complete All That Apply)						
	Previous Economizer Setpoint (°F, Btu/lb)					
	New Economizer Setpoint, if different (°F, Btu/lb)					
	Previous Minimum Outdoor Air (%)					
	New Minimum Outdoor Air (%), if different					
	Previous Maximum Outdoor Air (%)					
	New Maximum Outdoor Air (%), if different					
<ul style="list-style-type: none"> • Replace failed damper motor to allow proper damper modulation, if necessary. • Adjust linkage to allow proper damper modulation, as needed. Replace linkage if broken. • Repair wiring issues that prevent economizer operation. • Adjust the minimum damper position to meet the minimum required outdoor air. • Replace failed dry-bulb temperature and/or humidity sensors, as needed. • Replace failed economizer control modules, as needed. • Optimize the economizer setpoint if the unit is equipped with a fully operational economizer. Confirm the new setpoint meets space requirements. • Calculated incentive capped at 100% of tune-up cost. 						

Packaged Rooftop Unit Sealing

Ref ID	Measure Name	Unit	Air Conditioner Make & Model Number(s)	Quantity	Incentive (Per Unit)	Total Incentive
AC-08	Packaged Rooftop Unit Sealing	Each			\$30	\$
<ul style="list-style-type: none"> • Seal the interior and exterior seams that connect the economizer to the RTU using silicone caulking. • Seal supply and return duct seams inside of RTU with mastic. Seal leaks that are found around the perimeter of the roof to RTU connection with silicone caulking. • Seal all cabinet seams that are not typically removed during basic service (e.g., control panel) using silicone caulking. • Replace failed door panel gaskets. • Calculated incentive capped at 100% of product cost. • New construction projects are ineligible for rebate. 						

Product Information (cont.)

Advanced Rooftop Controls

Ref ID	Measure Name	Unit	RTU Make and Model	RTU Quantity	RTU Size (Tons)	Incentive (Per Ton)	Total Incentive
ARC-01	Advanced Rooftop Controls	Ton				\$60	\$
<ul style="list-style-type: none"> • Must be installed on unitary package rooftop unit (no split systems). • Existing rooftop unit must be less than 15 years old (based on manufacture date). • Must replace constant speed fan motor with either a supply fan VFD or multi-speed supply fan motor with controller that meets ventilation and space conditioning needs. • Must include digital, integrated economizer controls. • New construction or major renovation projects should apply for a custom rebate in order to confirm eligibility. • Must include CO2 sensor or occupancy sensor to determine ventilation and space conditioning needs for demand control ventilation (DCV). 							

Chillers

This measure is for installing chillers that operate the entire cooling season. Back-up chillers are ineligible. Multiple chiller projects should apply for a custom rebate.

Ref ID	Equipment Type	Equipment Size	Required IPLV	Chiller Model	Efficiency	Size (Tons)	Incentive (Per Ton)	Total Incentive
CHW-01	Electric Chiller - Air Cooled	All	≥16 IEER		IEER		\$30	\$
CHW-02	Electric Chiller - Water Cooled - Rotary Screw	<150 Ton	≤0.53 kW/ton		kW/ton		\$30	\$
CHW-03		150 Tons - 299 Tons	≤0.51 kW/ton		kW/ton		\$30	\$
CHW-04		≥ 300 Tons	≤0.47 kW/ton		kW/ton		\$30	\$
CHW-05	Electric Chiller - Water Cooled - Centrifugal	<150 Ton	≤0.52 kW/ton		kW/ton		\$30	\$
CHW-06		150 Tons - 299 Tons	≤0.52 kW/ton		kW/ton		\$30	\$
CHW-07		≥ 300 Tons	≤0.47 kW/ton		kW/ton		\$30	\$

Product Information (cont.)

Chiller Tune-Up

Chiller tune-ups shall include routine inspection for refrigerant leaks & volume, checking compressor operating pressures, all oil levels and pressures, crank case heater operation, and all electrical starters, contractors and relays, examining all motor voltages and amps, filter inspection and replacement when necessary, and cleaning of the coils or tubes. Additionally, water cooled chiller tune-up shall include chilled and condenser temperature adjustments, and compressor unloading switch adjustments.

Ref ID	Equipment Type	Chiller Type	Model Number	Chiller Size (Tons)	Quantity	Total Tons	Incentive (Per Ton)	Total Incentive
CHW-08	Electric Chiller Tune-Up	Air-Cooled Water-Cooled Centrifugal Water-Cooled Rotary Screw					\$5	\$

- Rebate is available once per year for each chiller.
- Calculated incentive capped at 100% of tune-up cost.
- Only lead chillers are eligible for this incentive.
- New construction projects are ineligible for rebate.

Variable Frequency Drives

The rebate applies to a variable frequency drives installed on an HVAC system pump or fan motor up to 100 hp. VFDs installed in industrial process applications should be submitted using the Miscellaneous Measure Selection Form. VFDs installed in other applications or those larger than 100 hp should be submitted for preapproval through the Custom Program prior to purchase. For New Construction Program participants, VFDs on fans less than 10 hp, VFDs on pumps less than or equal to 50 hp, and VFDs on any cooling tower fan are eligible for rebates. VFD incentives cannot be applied for if applying for Advanced Rooftop Controls incentives for the same equipment.

Ref ID	Equipment Type	Unit	HP per Motor (≤ 100 HP)	Motor Quantity	Application	Total HP	Incentive (Per Unit)	Total Incentive
VFD-01	Variable Frequency Drives on HVAC Pump & Cooling Tower Fan	HP			Cooling Tower Fan Chilled or Condenser Water Pump Hot Water Pump VFD		\$60	\$
VFD-02	Variable Frequency Drives on Supply & Return Air Fan	HP			Supply Air Fan Return Air Fan		\$60	\$